

Chiller Replacement and System Strategy



Timmins and District Hospital
L'Hôpital de Timmins et du district



Colin Berry – Account Manager

Current Situation

- 4 Existing RTAA chillers
 - All units 23 years old
 - Limited service history
 - One unit **MUST** be replaced immediately
 - One unit operating on single circuit
 - Two machines operating normally
-
- System has 4 chillers feeding a main chilled water line
 - Chilled water used for cooling of OR rooms
 - Critical cooling system, redundancy required.

Possible Option #1

- **OPTION 1**

- ▶ **Replace 4 existing chillers with 4 identical new chillers**
 - Fixes immediate deficiency
 - Will require heavy maintenance on remaining chiller(s) that will be replaced at a later date
 - Potential for chiller failure at any time
 - Lowest 1st capital cost
 - Limited expandability
 - No load shedding capability
 - Unable to take advantage of peak demand savings
 - Phase two would consist of replacing the remaining chillers at a later date.



Possible Option #2

- **OPTION 2**

- ▶ **Replace two chillers with a single Ice enhanced chiller, Phase 2 will add a second screw chiller to the system**
- ▶ **Fixes immediate deficiency**
 - **Less than five year payback on investment**
 - **Lowest life cycle cost**
 - **Leading technology with built in redundancy**
 - **Ice Storage system allows load shifting and lower ambient operational efficiency gains.**



Possible Option #2 Continued

- **OPTION 2**

- ▶ **Utility rates forecast to increase 40% in 5 years**
- ▶ **Time of day billing is imminent**
- ▶ **Future incentives may be available for load shifting to off peak**
- ▶ **Less mechanical equipment for future maintenance**
- ▶ **Packaged controls**
- ▶ **Remote monitoring of system to address problems before they occur**



Economics Review

Option #	Approximate Installed Cost	Yearly Utility Cost	1 st Year Maint.	Final Year Maint.
1	\$462,975	\$70,494	\$10,500	\$12,634
2	\$770,637	\$46,703	\$8,500	\$11,434

Note: Figures above do not include rebates

Rebates

- Hydro One offers a very enticing rebate program
- Based upon removing KW from the grid
- Thermal storage adds cooling tons while reducing mechanical system KW
- **This can fund a good portion of this project.**



Rebates – Review existing system

Air Cooled Series R® Chillers

File Edit Run Options Window Help

Air Cooled Series R® Chillers

RTAA Performance

Tag Selection Number

Model Number Run Result

Performance

Full Load Capacity	<input type="text" value="132.2"/> tons
Compressor Power	<input type="text" value="154.0"/> kW
Fan Power	<input type="text" value="12.6"/> kW
Total Power	<input type="text" value="167.4"/> kW
Unit Performance	<input type="text" value="9.5"/> EER

Capacity Per Circuit

Circuit One	<input type="text" value="66.6"/> tons
Circuit Two	<input type="text" value="65.6"/> tons

Ambient Temp deg F

Evaporator

Entering Temp	<input type="text" value="54.0"/> deg F	Flow Rate	<input type="text" value="316.3"/> gpm	Brine	<input type="text" value="WATER"/>
Leaving Temp	<input type="text" value="44.0"/> deg F	Pressure Drop	<input type="text" value="16.0"/> ft H2O	Percent Brine	<input type="text" value=""/>
Refrig. Temp	<input type="text" value="36.9"/> deg F	Fouling Factor	<input type="text" value="0.00010"/> hr-sq ft-deg F/Btu	Freeze Point	<input type="text" value="32.0"/> deg F

Rebates – Review direct replacement system

Unit Power =
132.6KW

New 130 ton
Trane CGAM

Electrical

Unit power:	132.60 kW
Total compressor power:	120.00 kW
Unit hertz:	60 hertz
Unit voltage:	575 volt 3 phases
Starter type:	Across the line
Incoming power line connection:	Single point
Power line connection type:	Circuit breaker
Enclosure type:	UL 1995 rated for outdoor applications
Number of fans:	10.00 Each
Fan motor power:	12.40 kW
Total fan FLA:	28.20 A

Rebates – Direct replacement calculations

Option 1:

replace all four existing chillers with new Scroll Chillers, controls

Current installed kW: $167 \times 4 = 668$ kW (4 X 130 ton chillers)

Future installed kW: $152 \times 4 = 608$ kW (4 X 130 ton chillers)

Rebate: $(668 - 608) \times \$800 =$

\$48,000

Phase 1: $[(167 \times 2) - (134.5 \times 2)] \times \$800 = \$24,000$ (Based on 2 replacements each phase)

Phase 2: $[(167 \times 2) - (134.5 \times 2)] \times \$800 = \$24,000$ (Based on 2 replacements each phase)

Installed cost: up: \$462,975 (Estimated budget after all phases completed)

After rebate first cost roll up: \$414,975

Total installed tons: 544 tons in 4 chillers

N-1 tons: 408 tons if one chiller is unavailable

Rebates – ICE Storage calculations

Option 2:

In three phases, replace all four existing chillers with 2 Screw chillers (178 tons) plus 9 tanks, controls

Current installed kW: $167 \times 4 = 668$ kW (4 X 130 ton chillers)

Future installed kW: $126 \times 2 = 252$ kW (2 X Trane chillers, thermal storage system)

Rebate: $(668 - 252) \times \$800 = \$332,800$

Phase 1: $[(167 \times 2) - 126] \times \$800 = \$166,400$

(1 new Trane chiller, remove 2 chillers)

Phase 2: no rebate (Install thermal storage system, 9 tanks)

Phase 3: $[(167 \times 2) - (126)] \times \$800 = \$166,400$

(1 new Trane chiller, remove 2 chillers)

Installed cost rolls up: \$ 770,637 (Estimated budget after all phases completed)

After rebate first cost roll up: \$ 504,397

Total installed tons: 536 tons in 2 chillers and 9 tanks N-1 tons: 403 tons if one chiller is unavailable assuming 25 tons per tank (6 hours of discharge, 12 hours of charge) (Capacity left – 1 chiller = 178 tons plus 25 tons X 9 tanks = 403 tons)

Energy Consumption Summary

	Yearly Savings vs Alt 2	Yearly Total Operating Cost (\$)	Yearly Utility Cost (\$)	Yearly Maintenance Cost (\$)	Plant kWh/ton-hr	
Alt 1	-23,790	70,494	70,494	0	0.933	1. like-for-like 341,352 kWh 365,864 ton-hr
Alt 2	0	46,703	46,703	0	0.776	2. thermal storage 287,462 kWh 370,440 ton-hr
Alt 3	-7,880	54,583	54,583	0	0.718	3. variable speed 263,355 kWh 366,789 ton-hr
Alt 4	-64,336	111,039	91,039	20,000	1.214	4. existing (base) 443,374 kWh 365,464 ton-hr

Notes:

Alt 1 – 4 New 130 ton chillers

Alt 2 – Ice Storage

Alt 3 – Variable speed Option (JCI Proposal)

Alt 4 – Existing Conditions.


What Does Trane Bring to the Table?

- Turnkey contracting service
- Controls, Service and Equipment from one supplier
 - ▶ Can tie into existing BMS
 - ▶ Preventative maintenance to avoid losing efficiency
 - ▶ Engineering and System Design
 - ▶ Project Management including rebates

We will be your single point of contact for the entire project and service period.


Similar First Cost...How?

- On air cooled chiller jobs
- Key is partial ice storage
- If not lower you likely have too much ice
- REBATES




Important Notes on ICE Systems

- ICE tanks can be viewed as chillers in series.
- General rule of thumb is that chiller can be sized to 65% of total cooling load.
- Not Only are night electrical rates lower but the air cooled chiller is more efficient at low ambient.
- Each ICE tank is roughly 25 tons peak discharge and 160 useable ton-hours.




Good Analogy for Partial ICE...

Hybrid Car



Hybrid Cooling



Partial Storage Basics

Hybrid Car

- Reduced size, efficient engine
 - ▶ Handles load most of the time
- Electric motors
 - ▶ Kick in when extra power is needed
- Electric motors
 - ▶ Are charged when plugged in, or braking, or by the engine

Hybrid Cooling

- “Right” sized chiller(s)
 - ▶ Handles load efficiently
- Storage tanks
 - ▶ Kick in when extra cooling is needed
- Storage tanks
 - ▶ Are efficiently charged at night when costs are low.

Both can have similar 1st cost!!!










Model Number - 1190A

Dimensions - OD x H	89" x 101"
Filled Weight	16765 lb
Floor Loading	388 lb/sq ft
Inlet-Outlet Flange Connection Size	2"
Manufacturer Product Line	ICEBANK®
Maximum Operating Pressure	90 psi
Maximum Operating Temperature	100 deg F
Net-Usable Capacity	162 ton-hr
Shipping Weight	1950 lb
Volume Of Water-Ice	1655 gal
Volume of Solution in HX	148 gal



Peak Design Load – 300 Tons

ICE percent	Chiller Capacity (tons)	Chiller Cost (\$500/ton)	No. of Tanks	Tank Cost	Total Cost
100% Full Storage	450	\$225k	18	\$270k	\$495k
80%	358	\$176k	14	\$210k	\$386k
60%	198	\$99k	10	\$150k	\$249k
40%	144	\$72k	6	\$90k	\$162k
0%	300	\$150k	0	0	\$150k



Why It Makes Sense for the Customer


Lower first costs (both new construction and existing buildings)

- If Chillers are being replaced.....
 - ▶ With a Combo of ice & chiller of same total capacity, properly sized, this can have basically have the same 1st cost.
 - ▶ **And adding ice to same size chiller, this will increase overall system capacity.**
- By keeping existing piping, pumps, and airside – this is now a great opportunity to use the colder water and add VFDs to save pump and potentially airside energy
- Or with reduced supply air temperature
 - ▶ Provide more cooling with same infrastructure
 - ▶ Eliminate hot spots
- Reduced maintenance cost because of less tonnage

Single Pump System


And We Can Keep These Systems Simple

- Lowest cost and simplest controls
- Often smaller systems
- But...There are a few things to be aware of.
 - ▶ Glycol throughout system
 - ▶ Night cooling with cold water




Existing Chiller Plants –

Two Alternatives that Keep It Simple, and solve one or both problems.





Eliminates the distribution of cold water during ice making, But still glycol in total system



No glycol in the distribution system


How Do You Make ICE Easy?






System Schematic

- *Schematic representation of plant layout*
- *At a glance view of key system operating parameters*



Trends and Gauges

- ***Dashboard style gauges and dials***
- ***Links to Trend Logs showing key data***



Savings Summary

- *Quantifies savings associated with Ice storage*
- *Simulates system energy use without Ice*
- *Visual breakout of peak kW and electrical consumption savings*


All Can be viewed...



AC Chillers + ICE Storage

Which can lead to...

- Lower temperature fluid
 - ▶ Can drive lower temperature air = less fan energy
 - ▶ Will increase chilled water ΔT on retrofits
- Larger chilled building loop ΔT
 - ▶ Drives lower flow rates = less pump energy
- AC chiller in series with ice storage tanks
 - ▶ Series arrangement supports Variable Primary Flow (VPF)
 - ▶ VPF saves on part-load pump energy
- All of the above help with earning LEED® points via reduced energy costs!



Decision To Use ICE?

